



LABORATORY TEST REPORT

Date:30.01.2015

1. Test done for : Om Concrete Products, 9 Gopal Chatterjee Road.
2. Letter Ref. No. : OPC/09/14-15, Dated 27.01.15
3. Name of the Work : Development of Sewerage Network and wastewater treatment facility for Gayeshpur Town.
4. Name of the Client : KMW & SA.
5. Name of the Agency: L&T.
6. Type of Test : Load Test of RCPC Manhole Cover as per IS12592:2002(Table-II)

Test Results:

Sl. No.	Id Mark	Type of Test	Permissible limit	Remarks
1	GPSP/1	Load Test	35 Mton.	OK

Note: - Tests were carried on the sample sent by the agency & with stand to take load up to 35 Mton.

Dr. Partha Ghosh
Assistant Professor
Mob. No.09433112189

Dr. Partha Ghosh
B.E. (Civil), M.E. (Structural Engg.), Ph.D (Engg.)
Assistant Professor
Construction Engg. Department
Jadavpur University, Kolkata - 98